

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1496:154 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Model FCPID-95 (Point Identification Device), FCSCE-95 (Signal Control Element), FCRCE-95 (Relay Control Element) analog/addressable modules. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: FCPID-95: 21 VDC
FCSCE-95: 24 VDC, Power-Limited
FCRCE-95: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with Gamewell's separately listed compatible Model Flex 620, 630 and 650 fire alarm control units (CSFM Listing No. 7165-1288:144 and 7170-1288:146).

XLF: 7300-1288:147



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 19, 2001

*Listing Expires **June 30, 2002***

Authorized By:

BEN HO, Supervising Deputy
Program Manager